CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.13/NH/CSR-5/847/CUBE/2015-16 29.06.2015

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

* Customer	: **Asst. Executive Engineer,** Shettyhalli Sub Division, Dasarahalli Zone, BBMP, Bangalore.
* Agency	: **Mr. Nagaraja Hosur,** No.133, 1st Main, 14th Cross, Soundarya Layout, Siddenahalli, Bangalore.
* Name of the work	: Improvements to Footpath 8th Cross road of Santhoshanagara, in ward No.13, in Shettyhalli Sub Division, BBMP, Bangalore.
* Reference	: BBMP/AEE/SSD/DZ/PR/2015-16 Dated: 22.05.2015
* Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
* Grade of Concrete	: M_{15}
Compressive Strength as on	: 28th day
Sample Received on	: 01.06.2015

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	01.06.2015	29.06.2015	8.155	352.3	15.66
2	01.06.2015	29.06.2015	8.235	360.5	16.02
3	01.06.2015	29.06.2015	8.305	372.5	16.56

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

AC-13

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com